



NOTE:

This detail is required only when pipe slope is 20% or greater.

SLOPE	MINIMUM ANCHOR SPACING, CENTER TO CENTER
0.20 - 0.34	35 feet
0.35 - 0.50	25 feet
0.51 +	15 feet or concrete encasement



City Of Beaverton

**ENGINEERING
DEPARTMENT**

CITY ENGINEER
Terry Waldele, P.E.

DATE
6 - 10 - 04

GRAVITY PIPE ANCHOR

DRAWN BY
JR - CPD

DRAWING NO.
307